# 2023 TULALIP UTILITIES WATER QUALITY REPORT



# **CONTACT INFORMATION:**

Please contact the numbers listed below if you would like more information about this report or for any questions related to your drinking water:

EPA's Hotline: 1 - 800 - 426 - 4791 Tulalip Utilities (360) 716 - 4840 TUA Fax: (360) 716 - 0700 Gus Taylor (360) 716 - 4011 Mike Leslie (360) 716 - 4840

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA) this report is designed to provide details about where you water comes from, what it contains and how it compares to standards set by regulatory agencies. This report is a snapshot of last years water quality. We are committed to providing you with information because informed customers are our best allies.

How can I get involved?

You may contact our office at 360-716-4840 for any inquiries, questions or concerns

# Is it ok to drink water from a garden hose?

Many hoses are made of PVC, a material that uses lead as a stabilizer. When water settles in these lead based hoses the concentration of lead increase 10 to 100 times the allowable limit set by the environmental health agency. However, you can purchase lead free hoses from your local store. Make sure that they state, "drink-safe", or, "safe for potable water" or "lead-free". This indicates that they are plated with nickel as opposed to lead.

\*Lead poisoning interferes with a variety of body processes and is very toxic to many of our organs and tissues. It interferes with the development of Our nervous system, thus is very harmful to the developmental process of our children so be sure to purchase hoses that will be safe for them play in and drink water from.

# Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency (EPA) Safe Drinking Water Hotline (800-426-4791).

tion Agency (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring and, in some cases radioactive material and substances resulting from the presence of animals or from human activity: microbial contaminants such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants such as salts and metals which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas productions, mining, or farming; pesticides and herbicides which may come from a variety of sources such as agriculture, urban storm water runoff and residential uses; chemical contaminants including synthetic and volatile organic chemicals which are byproducts of industrial processes and petroleum production and can also come from gas stations, urban storm water run-off and septic systems. systems.

In order to ensure that tap water is safe to drink the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems (PWS). Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

# ADDITIONAL INFORMATION **FOR LEAD:**

If present elevated lead levels can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Tulalip Utilities Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours you can minimize your lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at::http:// www.epa.gov/safewater/lead

### How is my water treated?

Your water is treated by disinfection. Dis-infection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

#### Where can I find source water assessment and its availability?

You may contact Tulalip Utilities at 360-716-4840 to inquire about this information.

# How can I help conserve water?

The average U.S household uses approximately 400 gallons of water per day or 100 gallons per person per day. There are many low-cost and no-cost ways to conserve water. Small changes can make a big difference!

- Take shorter showers— a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month
- Use a water-efficient showerhead. They are inexpensive, easy to install and can save up to 750 gallons a month Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month
- The average car wash uses over 30 gallons of water
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing you have a leak. Fixing it or replacing with a new model can save up to 1,000 gallons a month
- Adjust sprinklers so only your lawn and flowers are watered. Apply water only as fast as the soil can absorb it and only water during the coolest parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure future generations use water wisely.
- Visit www.epa.gov/watersense for more information



# Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or <a href="http://water.epa.gov/drink/hotline">http://water.epa.gov/drink/hotline</a>

### How many contaminants are regulated in drinking water?

The U.S. EPA regulates over 80 contaminants in drinking water. Some states may choose to regulate additional contaminants or to set stricter standards, but all states must have standards at least as stringent as the U.S. EPA's. Each well site has there own set of standards and regulations that are imposed and carefully supervised year round.

### How can I help protect our valuable source water?

Protection of drinking water is everyone's responsibility. There are a number of ways in which you can help to protect your communities water source:

- Eliminate excess use of lawn and garden fertilizers and pesti-cides—they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
  If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public sewer system
- Dispose of chemicals properly, take used motor oil to a recycling center
- Volunteer in your community. Find a watershed or wellhead protection organization in your community or visit the Watershed Information Networks How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to street drains reminding people "Dump No Waste—Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

# Why do I get this report every year?

Community water system operators are required by Federal law to provide their customers an annual water quality report. The report helps people make informed choices about the water they drink. It lets people know what contaminants, if any, are in their drinking water and how these contaminants may affect their health. It also gives the system operators a chance to tell customers what it takes to deliver safe drinking water.

# How much water is used in a typical shower?

The Federal Energy Policy Act (FENPA) set a nationwide regulation that limits showerheads to a maximum flow of 2.5 gallons per minute (GPM). Showerheads made before 1980 are rated at 5 GPM. Since the average shower is estimated to last 8.2 minutes, the old showerheads use 41 gallons of water while the newer, low-flow showerheads use only about 21 gallons gallons. Prepared by RMJ

Tulalip Bay #105300003									
CONTAMINANT	DATE	HIGHEST DETECTED	RANGE DETECTED	MCLG	MCL	VIOLATION	LIKELY SOURCE OF CONTAMINANT		
Chlorine (ppm)	2023	0.6	0.5-0.6	MRDLG = 4	MRDL = 4	NO	Water additive used to control microbes		
HAA5 (ppb)	2023	30	19.3 - 28.1	No goal for the total	60	NO	By-product of drinking water disinfection		
TTHM (ppb)	2023	42	38.8 - 58	No goal for the total	80	NO	By-product of drinking water disinfection		
Nitrate (ppm) (measured as Nitrogen)	2023	.01	0.01—.01	10	10	NO	Runoff from fertilizers; Septic tanks/sewage leaching; Erosion		
CONTAMINANT	DATE	MCLG	AL	90TH %	#OVER AL	VIOLATION	LIKELY SOURCE OF CONTAMINANT		
Copper (ppm)	2023	1.3	1.3	0.0237	0	NO	Erosion; Leaching from wood preservatives; corrosion of household plumbing.		
Lead (ppb)	2023	0	15	0.4	0	NO	Corrosion of household plumbing; Erosion of Natural Deposits		

# \*\*TULALIP BAY WATER DISTRICT 1\*\*

https://everettwa.gov/archivecenter/viewfile/item/1232

tem is supplied by surface water from the City of Everett. The water source is Spada Lake, 30 miles east in the Cascade Mountains. Tulalip Bay water system serves approximately 5440 persons. The system now also serves approximately 360 persons at Aspen Estates as well as approximately 168 persons from the former John Sam Lake system. The system currently has 1,811 residential connections and 97 nonresidential connections. Typical demand is 1.0 MGD and peak demand is approximately 2.0 MGD. Disinfection is supplied by the city of Everett. Everett maintains a 1.0 mg/l fluoride concentration in the water supplied to the Tulalip Bay system.

**TULALIP BAY** The Tulalip Bay water sys-

### COLIFORM BACTERIA

M	ICLG	TOTAL COLIFORM MCL	HIGHEST # POSITIVE	FECAL COLIFORM OR E. COLI MCL	IOTAL # OF POSITIVE E. COLI OR		LIKELY SOURCE OF CONTAMINANT
	0	1 positive monthly sample	1	A routine sample and a repeat sample are total coliform positive, and one is also fecal coliform or E. coli positive		NO	Naturally present in environment

#### UNREGULATED CONTAMINANTS

Tulalip Utilities collected quarterly samples at the entry point to the Tulalip Bay water distribution system according to the Fifth Unregulated Contaminant Rule (UCMR5). These samples were tested for 30 per-and polyfluoroalkyl substances (PFAS) and lithium. NO PFAS OR LITHIUM WERE DETECTED

<sup>\*</sup>Source water testing results can be obtained from the City of Everett's water quality report at:

DELIA JIMICUM #105300135										
CONTAMINANT	DATE	HIGHEST	RANGE DETECTED	MCLG	MCL	VIOLATION	LIKELY SOURCE OF CONTAMINANT			
Chlorine (ppm)	2023	0.6	0.4 - 0.6	MRDLG = 4	MRDL = 4	NO	Water additive used to control microbes			
TTHM (ppb)	2022	2.1	2.1 - 2.1	No goal for the total	80	NO	By-product of drinking water disinfection			
**Arsenic (ppb)	2019	5.5	5.5 - 5.5	0	10	NO	Erosion; Run-off from orchards and glass and electronics production wastes			
Barium (ppm	2019	0.0078	0.0078 - 0.0078	2	2	NO	Discharge of drilling wastes and metal refineries; Erosion			
Chromium (ppb)	2019	3.4	3.4 - 3.4	100	100	NO	Discharge from steel and pulp mills; erosion of natural deposits.			
Nitrate (ppm) (measured as nitrogen)	2023	2	1.67 - 1.67	10	10	NO	Run-off from fertilizer use; Septic tanks/sewage leaching; Erosion			
CONTAMINANT	DATE	MCLG	90TH %	AL	# Over AL	VIOLATION	LIKELY SOURCE OF CONTAMINANT			
Copper (ppm)	2021	1.3	0.267	1.3	0	NO	Erosion; Leaching from wood preservatives; Corrosion of household plumbing			
Lead (ppb)	2021	0	0.4	15	0	NO	Corrosion of household plumbing systems; Erosion			

# **DELIA JIMICUM**

The Delia Jimicum system consists of 12 residential connections serving approximately 42 persons. The water is supplied by one ground water well, with a 5,000 gallon capacity storage tank. Water production is estimated at 2,100 gals/day. Disinfection is accomplished by injecting dilute sodium hypochlorite solution when the well pump is pumping to the reservoir.

MADISON ESTATES #105300144									
CONTAMINANTS	DATE	HIGHEST	RESULTS	MCLG	MCL	VIOLATION	LIKELY SOURCE OF CONTAMINANT		
Chlorine (ppm)	2023	0.8	0.7 - 0.8	MRDLG = 4	MRDL = 4	NO	Water additive used to control microbes		
TTHM (ppb)	2021	1.9	1.9 - 1.9	No goal for the total	80	NO	By-product of drinking water disinfection		
** Arsenic (ppb)	2022	5	5 - 5	0	10	NO	Erosion of natural deposits; Run-off from orchards and glass/electronics production wastes.		
Barium (ppm)	2019	0.0099	0.0099 - 0.0099	2	2	NO	Discharge of drilling waste/metal refineries; Erosion. Can increase blood pressure		
Chromium (ppb)	2019	2.7	2.7 - 2.7	100	100	NO	Discharge from steel and pulp mills; erosion of natural deposits.		
Nitrate (ppm) (measured as Nitrogen)	2023	1	0.784 - .784	10	10	NO	Runoff from fertilizer; Septic tank/sewage leaching; erosion		
CONTAMINANT	DATE	MCLG	90TH %	AL	# OVER AL	VIOLATION	LIKELY SOURCE OF CONTAMINANT		
Copper (ppm)	2021	1.3	0.45	1.3	0	NO	Erosion; Leaching from wood preservatives; Corrosion of household plumbing		
Lead	2021	0	1.1	15	0	NO	Corrosion of household plumbing; Erosion of natural deposits		

# MADISON ESTATES

The Madison estates water system consists of 25 water connections serving approximately 86 persons. The water is supplied by one ground water well with an above ground concrete storage tank with a capacity of 49,000 gallons. Average production is estimated at 9,636 gals/day. Disinfection is accomplished by injecting dilute sodium hypochlorite solution when the well pump is pumping to the reservoir.

TULARE ESTATES #105300155									
CONTAMINANT DATE HIGHES		HIGHEST	HIGHEST RESULTS		MCL	VIOLATION	LIKELY SOURCE OF CONTAMINATION		
Chlorine (ppm)	2023	0.8	0.5 - 0.8	MRDLG = 4	MRDL = 4	NO	Water additive used to control microbes		
HAA5 (ppb)	2022	4.4	4.4 - 4.4	No goal for the total	60	NO	By-product of drinking water disinfection		
TTHM (ppb)	2022	15.7	15.7 - 15.7	No goal for the total	80	NO	By-product of drinking water disinfection		
** Arsenic (ppb)	2019	2	2 - 2	0	10	NO	Erosion; Run-off from orchards; glass/electronic production Wastes		
Barium (ppm)	2019	0.0068	0.0068 - 0.0068	2	2	NO	Discharge of drilling wastes/metal refineries; Erosion. Can increase blood pressure		
Fluoride (ppm)	2019	0.14	0.14 - 0.14	4	4	NO	Erosion; discharge from fertilizer and aluminum factories; Water additive which promotes strong teeth		
Nitrate (ppm) (measured as Nitrogen)	2023	0.011	0.011 - 0.011	10	10	NO	Run-off from fertilizer use; Septic tanks/sewage leaching; Erosion		
CONTAMINANT	DATE	MCLG	90TH %	AL	# Over AL	VIOLATION	LIKELY SOURCE OF CONTAMINANT		
Copper (ppm)	2022	1.3	0.0923	1.3	0	NO	Erosion; Leaching from wood preservatives; Corrosion of household plumbing		
Lead (ppb)	2022	0	0.9	15	0	NO	Corrosion of household plumbing systems; Erosion		

### **TULARE**

The Tulare system consists of 12 connections serving approximately 35 persons. Water is supplied by one groundwater well with an above ground concrete storage tank with a capacity of 29,000 gallons. Typical water production is estimated to be approximately 3,800 gal/day. Disinfection is accomplished by injecting dilute sodium hypochlorite solution when the well pump is pumping to the reservoir.

\*\* While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. (40 CFR§141.155)





When you turn on your faucet, water seems to magically appear. EPA, states, and water utilities work together to bring clean, safe water into homes and businesses every day.

In the US, approximately 90% of the population gets drinking water from a public water system (PWS) that treats, stores, and distributes the water.





# **IMPORTANT DRINKING WATER TERMS & DEFINTIONS**

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best

available treatment technology and taking cost into consideration. MCLs are enforceable standards.

Maximum contaminant level goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Maximum residual disinfectant level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for control of microbial contaminants

Maximum residual disinfection level goal (MRDLG) - The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not

reflect the benefits of the use of disinfectants to control microbial contaminants.

**ACTION LEVEL (AL)** - The concentration of a contaminant that, if exceeded triggers treatment or other requirements that a system must follow.

# **ABBREVIATIONS:**

Mg/L - Milligrams per liter

Parts per million PPM -

Parts per billion PPB -

**TTHM:** Total Trihalomethanes

HAA5: Haloacetic Acid

